

MONTCLAIR STATE UNIVERSITY

Montclair, NJ 07043

ADDENDUM NO. 1611

Request for Proposal # 1611 UPS Systems

Date of Original Bidding Documents: December 17, 2024

Date of Addendum No. 1: January 17, 2025

Bid Opening Date: February 3, 2025

INTENT: This Addendum forms a part of the Contract Documents and modifies the Original Bidding Documents and Prior Addenda, if any, as identified above. Unless specifically noted or specified hereinafter, all work shall comply with the applicable provisions of the Contract Documents.

It is the sole responsibility of the Bidder to be knowledgeable of all of the additions, deletions, clarifications and modifications to the RFP relative to this RFP as set forth in all addenda. Bidders should acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

I. ANSWERS TO QUESTIONS:

#	RFP Section Reference	Question (Bolded) and Answer
1	4.8.3	<u>Question:</u> Does section 4.8.3 Public works Contractor registration Apply to this RFP? <u>Answer:</u> Yes, this section applies to the RFP.
2	3.1	<u>Question:</u> Are the PMs to occur normal business hours, after hours, or weekends <u>Answer:</u> MSU Facilities prefers PM's visits be scheduled M-F, 7:30am – 4:00pm. However, if the contractor needs other times, MSU will accommodate.

#	RFP Section Reference	Question (Bolded) and Answer																																								
3	3.5	<p>Question: For the Option Service – Operational Test, please provide length of cable requirement for each location and the duration of test required...also would these be priced for normal hours /after hours or / weekend hours?</p> <p>Answer: UPS battery banks and controls sit side by side; internal UPS cable lengths are unknown. All work to be priced/completed, M-F, 7:30am – 4:00pm. If contractor needs to schedule site time outside these times, MSU will accommodate.</p>																																								
4	3.1	<p>Question: What are the kVA sizes for each of the UPS units?</p> <p>Answer: The UPS models information outlined in RFP Section 3.1 has been amended to include the Vac In/Out and KW Out information as shown below:</p> <table border="1" data-bbox="480 751 1430 1272"> <thead> <tr> <th>MSU ID</th> <th>MSU RM #</th> <th>Manuf. Name</th> <th>VAC IN/OUT</th> <th>KW OUT</th> </tr> </thead> <tbody> <tr> <td>SCOM-UPS-01</td> <td>SCOM-00-0028</td> <td>Eaton 93PM</td> <td>480</td> <td>130</td> </tr> <tr> <td>COLE-UPS-01</td> <td>COLE-00-190A</td> <td>Vertiv Liebert EXM</td> <td>480</td> <td>200</td> </tr> <tr> <td>UNIV-UPS-01</td> <td>UNIV-06-6036</td> <td>MGE UPS System, Galaxy PW</td> <td>480</td> <td>225</td> </tr> <tr> <td>UNIV-UPS-02</td> <td>UNIV-06-6036</td> <td>MGE UPS System, Galaxy PW</td> <td>480</td> <td>225</td> </tr> <tr> <td>CHPN-UPS-01</td> <td>CHPN-00-G25B</td> <td>Myers, Illuminator Central Inverter System</td> <td>208</td> <td>24</td> </tr> <tr> <td>SBUS-UPS-01</td> <td>SBUS-00-0091</td> <td>Emerson Network Power, Liebert NX</td> <td>480</td> <td>100</td> </tr> <tr> <td>OVLK-UPS-01</td> <td>OVLK-03-3725</td> <td>Eaton 93E</td> <td>208</td> <td>60</td> </tr> </tbody> </table>	MSU ID	MSU RM #	Manuf. Name	VAC IN/OUT	KW OUT	SCOM-UPS-01	SCOM-00-0028	Eaton 93PM	480	130	COLE-UPS-01	COLE-00-190A	Vertiv Liebert EXM	480	200	UNIV-UPS-01	UNIV-06-6036	MGE UPS System, Galaxy PW	480	225	UNIV-UPS-02	UNIV-06-6036	MGE UPS System, Galaxy PW	480	225	CHPN-UPS-01	CHPN-00-G25B	Myers, Illuminator Central Inverter System	208	24	SBUS-UPS-01	SBUS-00-0091	Emerson Network Power, Liebert NX	480	100	OVLK-UPS-01	OVLK-03-3725	Eaton 93E	208	60
MSU ID	MSU RM #	Manuf. Name	VAC IN/OUT	KW OUT																																						
SCOM-UPS-01	SCOM-00-0028	Eaton 93PM	480	130																																						
COLE-UPS-01	COLE-00-190A	Vertiv Liebert EXM	480	200																																						
UNIV-UPS-01	UNIV-06-6036	MGE UPS System, Galaxy PW	480	225																																						
UNIV-UPS-02	UNIV-06-6036	MGE UPS System, Galaxy PW	480	225																																						
CHPN-UPS-01	CHPN-00-G25B	Myers, Illuminator Central Inverter System	208	24																																						
SBUS-UPS-01	SBUS-00-0091	Emerson Network Power, Liebert NX	480	100																																						
OVLK-UPS-01	OVLK-03-3725	Eaton 93E	208	60																																						
5	3.5	<p>Question: The RFP states, "When requested, the Contractor must be able to complete an operational test, including a monitored, battery-rundown to calculate if the batteries are near the end of their life." FGC can facilitate this however, it would require Montclair State University to either use your connected load as the load or FGC would need to bring in a Load Bank. We need clarification on the details of the load as there is a difference in cost.</p> <p>Answer: Using actual working loads will be acceptable for this rare request, a load bank is not required.</p>																																								

Please acknowledge receipt of this Addendum No. 1 via the following email address: Zinenkok@montclair.edu

Company Name (please print)

Date

Signature

Title

Contact Name (please print)